

# Certificate

No. **z4340a-16-E**

**Customer:**

Dätwyler Cables GmbH  
Auf der Roos 4-12  
65795 Hattersheim, Germany

**Class Ea**

**Test sample(s):**

Data Cable:  
**DATWYLER CU 7080 4P AWG23 S/FTP Cat.7 FRNC/LSZH**  
Part no.: 182911

CP-Cable:  
**DATWYLER CP1-77024-GRH-05M0-45SDSGRM/45SDSGRM-A01**  
Part no.: 653516

Connector:  
**DATWYLER RJ45 module KS-T Plus 1/8 tool-less Cat.6A (IEC) shielded**  
Part no.: 418061

**Applied standard(s):**

ISO/IEC 11801 Ed.2.2 (2011-06)

**Result(s):**

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

## 3 Connector Permanent Link , Copper, Class Ea

## GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **P4340a-16-E** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of issue.

Bexbach, 01. August 2016



Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



**GHMT AG**  
In der Kolling 13  
66450 Bexbach / Germany

P0 box 11 16  
66442 Bexbach / Germany

T: +49 6826 92 28-0  
F: +49 6826 92 28-290

info@ghmt.de  
www.ghmt.de

**RELIABILITY IN TOTAL  
REQUIRES ACCURACY IN DETAIL.**