

Certificate

No. **z5591a-19-E**

Customer:

Dätwyler Cables GmbH
Auf der Roos 4-12
65795 Hattersheim, Germany

Class Ea

Test sample(s):

Data Cable:
DATWYLER CU 7080 4P AWG23 S/FTP Cat.7 FRNC
Part no.: 182911xxxx

CP-Cable:
**DATWYLER patch cord Cat.6A (IEC) shielded, wiring 1:1 with
DATWYLER RJ45 module KS-TC Plus Cat.6A (IEC) tool-less-shielded**
Art.-Nr.: 653516 / 653526 with 418069

Connector:
DATWYLER RJ45 module KS-TC Plus Cat.6A (IEC) tool-less-shielded
Part no.: 418069

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Result(s):

The sample meets the limits of the applied standards and regulations with respect to the parameters indicated above.

3 Connector Permanent Link, Copper, Class Ea

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **P5591a-19-E** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of issue.

Bexbach, 30. August 2019



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 13
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**