

## Certificate of Product Approval

Certificate Number: 172g

Issue: 03

### DÄTWYLER IT INFRA AG

Gotthardstrasse 31  
CH-6460 Altdorf  
Switzerland



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
DFS ST

#### Standard(s) (see Appendix for details)

BS 7629-1:2015  
BS 6387:2013 (CWZ)  
EN 50200:2015 (Class PH120)  
EN 50200:2015 Annex E (30 mins)  
EN 60332-3-24:2009  
EN 60332-3-25:2009  
BS 5839-1:2013 (Clause 26.2d Standard)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Piracha*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Scheme Manager

13 November 2020  
Date of Issue

2 October 2017  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB® is a registered trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 172g DÄTWYLER IT INFRA AG

Issue: 03

Product name						LPCB Ref. No.
DFS ST						172g/01
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction (excluding drain wire and earth)	BS 7629-1	BS 6387	EN 50200	EN 50200 Annex E	BS 5839-1 Clause 26.2
1.0 <sup>(1)</sup>	2	STANDARD 60 <sup>(3)</sup>	C, W, Z	Class PH120	30min <sup>(4)</sup>	Standard <sup>(5)</sup>
1.5 <sup>(1)</sup>	2, 3 & 4	STANDARD 60 <sup>(3)</sup>	C, W, Z	Class PH120	30min <sup>(4)</sup>	Standard <sup>(5)</sup>
2.5 <sup>(1)</sup>	2, 3 & 4	STANDARD 60 <sup>(3)</sup>	C, W, Z	Class PH120	30min <sup>(4)</sup>	Standard <sup>(5)</sup>
4.0 <sup>(2)</sup>	2, 3 & 4	STANDARD 60 <sup>(3)</sup>	C, W, Z	Class PH120	30min <sup>(4)</sup>	Standard <sup>(5)</sup>

### Uo/U 300/500V

#### Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. In meeting the requirements of BS 7629-1:2015, the DFS ST cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, achieved less than 0.5%HCl for the outer covering, binder tape and insulation when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
4. The duration of 30 min when tested in accordance with EN 50200:2015 Annex E is achieved by 15min for the fire and mechanical shock phase and an additional 15min for the fire, mechanical shock and water phase.
5. The DFS ST cables listed conform to BS 7629-1:2015, met Class PH120 when tested in accordance with EN 50200:2015 and met the 30min duration when tested in accordance with EN 50200:2015 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.
6. Where the cable diameter is greater than 12mm the cable is additionally approved to EN 60332-3-24.
7. Where the cable diameter is equal to or less than 12mm the cable is additionally approved to EN 60332-3-25.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*Obada Aléer*

Signed for BRE Global Ltd.

Obada Piracha  
Certification Scheme Manager

13 November 2020  
Date of Issue

2 October 2017  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a registered trademark of the Building Research Establishment Ltd.

